

EncounterId:	690,079	Asset:	M054 - I.S. 54 - MANHATTAN
Inspection Type:	Electrical	Time In:	10/13/2004 10:53:27AM
Inspector:	Ornektekin, Ozgem	Time Out:	10/13/2004 12:46:21PM
Last Edited By:	Hansalia, Vallabh	Last Edited:	5/17/2005 4:46:23PM

Question	Answer
Quantity UOM	Each
Potential Action	Replace
Urgency Of Action	Priority 5
Purpose Of Action	Level 3
Violations?	No
<b>LIGHTING - STAGE THEATER</b>	
Exists?	Yes
Building Replacement	
Replacement Quantity	96
Replacement Quantity UOM	Each
Condition	4- Between Fair and Poor
Deficiencies?	Yes
Deficiencies	
Deficiency Type	Lighting Fixture Antiquated/obsolete
Deficiency Location/instance	Stage
Deficiency Quantity	96
Quantity UOM	Each
Potential Action	Replace-upgrade
Urgency Of Action	Priority 4
Purpose Of Action	Level 2
Violations?	No
<b>LIGHTING - STAGE THEATER, DIMMING SYSTEM WITH REMOTE CONTROL</b>	
Exists?	Yes
Building Replacement	
Replacement Quantity	1
Replacement Quantity UOM	Each
Condition	5- Poor
Deficiencies?	Yes
Deficiencies	
Deficiency Type	Lighting Controller Not Operational
Deficiency Location/instance	Stage
Deficiency Quantity	1
Quantity UOM	Each
Potential Action	Replace
Urgency Of Action	Priority 4
Purpose Of Action	Level 2
Violations?	No
<b>LIGHTING FIXTURE - FLUORESCENT</b>	
Pendant Mounted	
Exists?	Yes
Condition	3- Fair
Deficiencies?	No
Recessed Mounted	
Exists?	No
Surface Mounted	